



Bankverbindungen:  
Deutsche Bank AG, Frankfurt  
Kto.-Nr. 600011100, BLZ 500 70010  
Sparkasse Siegen  
Kto.-Nr. 30 375 984, BLZ 460 500 01

USt-IdNr.: DE 164903772

St-Nr. LH 5214/5822/0047

Telefon 02 71/77 50-3  
Telefax 02 71/77 50-500  
E-Mail lsg-elab@lsg-elab.de

LSG-ELAB GmbH  
Birlenbacher Str. 14, D-57078 Siegen

**Schäfer-Werke GmbH**  
z. Hd. Herrn Sebastian Hilpisch  
Pfannenbergstr. 1

**57290 Neunkirchen**



DAP-PL-3072.00  
DAP-ZE-3072.01

Ihr Zeichen/Datum	Unsere Durchwahl	Unsere Telefax-Durchwahl	Unser Zeichen/Datum
	-464	-501	sm/ 23.02.2004

<b>Test-Report</b>	<b>W04-00673M</b>
<b>Order:</b>	Analysis
<b>Customer:</b> .....	Schäfer-Werke GmbH z. Hd. Herrn Sebastian Hilpisch Pfannenbergstr. 1  57290 Neunkirchen

Results of W04-00673M from 12.02.2004.

**Test-Report**
**W04-00673M**

**Customer:** Schäfer-Werke GmbH, Neunkirchen  
**Appearance:** colourless / clear  
**Sampling site:** DWS 30 manual, Sample from dispensing valve after disinfection  
**Sampling date:** 12.02.2004 / 16:00 Uhr      **Operator:** Laboratory  
**Date of testing (start):** 12.02.2004      **Date of testing (end):** 23.02.2004

Parameter	Dimension	Result	Limit (TrinkwV)		Procedure
			not under	not over	
Colony count 20 °C	1/ml	0		100	TrinkwV a.F.*
Colony count 36 °C	1/ml	0		100	TrinkwV a.F.*
E. coli	1/100ml	0		0	ISO 9308-1*
Coliforms	1/100ml	0		0	ISO 9308-1*
P. aeruginosa	1/100ml	0		0	prEN ISO 12780*


Notes: \* = certified parameter; \*\* = parameter examined in a other certified institute; n.n. = not detected; n.b. = not analysed

Remarks only in relation to examined microbiological parameters.

**Comments:**  
 System filled by orderer on February 12th 2004.  
 Content of DWS 30 manual: approx. 15 l.  
 Origin of water: Herdorf purification plant, 3rd level of water purification (see W04-00672M).

**Sample evaluation:**  
 The results meet the requirements for drinking water given by the german drinking water regulation.

LSG-ELAB GmbH



Oliver Schulte-Mäter  
Food Chemist